

A Service of



Leibniz-Informationszentrum Wirtschaft Leibniz Information Centre for Economics

Safarian, Sahar; Aramoun, Fereshteh

# **Article**

# Energy and exergy assessments of modified Organic Rankine Cycles (ORCs)

Energy Reports

# **Provided in Cooperation with:** Elsevier

*Suggested Citation:* Safarian, Sahar; Aramoun, Fereshteh (2015) : Energy and exergy assessments of modified Organic Rankine Cycles (ORCs), Energy Reports, ISSN 2352-4847, Elsevier, Amsterdam, Vol. 1, pp. 1-7, [https://doi.org/10.1016/j.egyr.2014.10.003](https://doi.org/10.1016/j.egyr.2014.10.003%0A)

This Version is available at: <https://hdl.handle.net/10419/187809>

# **Standard-Nutzungsbedingungen:**

Die Dokumente auf EconStor dürfen zu eigenen wissenschaftlichen Zwecken und zum Privatgebrauch gespeichert und kopiert werden.

Sie dürfen die Dokumente nicht für öffentliche oder kommerzielle Zwecke vervielfältigen, öffentlich ausstellen, öffentlich zugänglich machen, vertreiben oder anderweitig nutzen.

Sofern die Verfasser die Dokumente unter Open-Content-Lizenzen (insbesondere CC-Lizenzen) zur Verfügung gestellt haben sollten, gelten abweichend von diesen Nutzungsbedingungen die in der dort genannten Lizenz gewährten Nutzungsrechte.

# **Terms of use:**

*Documents in EconStor may be saved and copied for your personal and scholarly purposes.*

*You are not to copy documents for public or commercial purposes, to exhibit the documents publicly, to make them publicly available on the internet, or to distribute or otherwise use the documents in public.*

*If the documents have been made available under an Open Content Licence (especially Creative Commons Licences), you may exercise further usage rights as specified in the indicated licence.*



<https://creativecommons.org/licenses/by-nc-nd/4.0/>





#### [Energy Reports 1 \(2015\) 1–7](http://dx.doi.org/10.1016/j.egyr.2014.10.003)

Contents lists available at [ScienceDirect](http://www.elsevier.com/locate/egyr)

Energy Reports

journal homepage: [www.elsevier.com/locate/egyr](http://www.elsevier.com/locate/egyr)

# Energy and exergy assessments of modified Organic Rankine Cycles (ORCs)

# Sahar Safarian[∗](#page-1-0) , Fereshteh Aramoun

*Department of Energy Engineering, Sharif University of Technology, Tehran, P.O. Box 11365-11155, Iran*

#### ARTICLE INFO

*Article history:* Received 30 August 2014 Received in revised form 7 October 2014 Accepted 16 October 2014 Available online 9 January 2015

*Keywords:* Exergy analysis Organic Rankine Cycle Regeneration Turbine bleeding

#### A B S T R A C T

This paper presents a theoretical framework for the energy and exergy evaluation of a basic as well as three modified Organic Rankine Cycles (ORCs). The modified ORCs considered incorporating turbine bleeding, regeneration and both of them. The results demonstrate that evaporator has major contribution in the exergy destruction which is improved by increase in its pressure. The results confirm that the integrated ORC with turbine bleeding and regeneration has the highest thermal and exergy efficiencies (22.8% and 35.5%) and the lowest exergy loss (42.2 kW) due to decrease in cold utility demand and high power generation.

as the thermal pollution.

[Li](#page-7-7) [et al.,](#page-7-7) [2011\)](#page-7-7).

© 2014 The Authors. Published by Elsevier Ltd. This is an open access article under the CC BY-NC-ND license [\(http://creativecommons.org/licenses/by-nc-nd/4.0/\)](http://creativecommons.org/licenses/by-nc-nd/4.0/).

order to meet future energy demand while reducing greenhouse gas emissions and dependence on fossil fuels, development of energy systems is inescapable. Study shows that more than 50% of the total heat generated in industry is the low grade heat and is wasted

Among many well-proven technologies, Organic Rankine Cycle (ORC) is considered to be an effective solution for low and medium temperature (300–450 °C) heat recovery for power production. The important advantage of ORC is that it can be successfully used in various fields of biomass combustion, geothermal systems, solar desalination systems, and it is extremely beneficial when the exhaust gases of the gas turbine are at low temperature. High reliability and flexibility also contribute at making the value proposition of ORC particularly attractive [\(Bombarda](#page-7-0) [et al.,](#page-7-0) [2010;](#page-7-0) [Munoz](#page-7-1) [de](#page-7-1) [Escalona](#page-7-1) [et al.,](#page-7-1) [2012;](#page-7-1) [Chacartegui](#page-7-2) [et al.,](#page-7-2) [2011;](#page-7-2) [Karellas](#page-7-3) [et al.,](#page-7-3) [2012;](#page-7-3) [Sun](#page-7-4) [and](#page-7-4) [Li,](#page-7-4) [2011;](#page-7-4) [Wei](#page-7-5) [et al.,](#page-7-5) [2008;](#page-7-5) [W.](#page-7-6) [Li](#page-7-6) [et al.,](#page-7-6) [2011;](#page-7-6) [J.](#page-7-7)

[Quoilin](#page-7-8) [et al.](#page-7-8) [\(2011\)](#page-7-8) focused both on the thermodynamic and economic optimization of a small-scale ORC in waste heat recovery application. [Sun](#page-7-4) [and](#page-7-4) [Li](#page-7-4) [\(2011\)](#page-7-4) optimized the performance of an ORC based on two objective functions. They demonstrated that the controlled variables and uncontrolled variables are linear function for maximizing the total net power generation and quadratic

In addition, there are some methods that can improve an ORC system performance, such as system operating optimization, combining feed-water heating, integrating with other system techniques and incorporating turbine bleeding and regeneration. In this way, [Mago](#page-7-9) [et al.](#page-7-9) [\(2008\)](#page-7-9) and [Desai](#page-7-10) [and](#page-7-10) [Bandyopadhyay](#page-7-10) [\(2009\)](#page-7-10) have

function for maximizing the system thermal efficiency.

#### **Nomenclature**



#### **1. Introduction**

Energy consumption is increasing and the rapid industrialization leads to global warming and environmental deterioration. In

<span id="page-1-0"></span>∗ Corresponding author. Tel.: +98 21 22374487. *E-mail address:* [safarian@energy.sharif.edu](mailto:safarian@energy.sharif.edu) (S. Safarian).

<http://dx.doi.org/10.1016/j.egyr.2014.10.003>







<sup>2352-4847/</sup>© 2014 The Authors. Published by Elsevier Ltd. This is an open access article under the CC BY-NC-ND license [\(http://creativecommons.org/licenses/by-nc-nd/4.](http://creativecommons.org/licenses/by-nc-nd/4.0/)  $0$ ).

<span id="page-2-0"></span>

**Fig. 1.** Schematic diagram of (a) basic ORC, (b) modified ORC incorporating turbine bleeding, (c) regenerative ORC and (d) modified ORC incorporating both turbine bleeding and regeneration.

shown that the thermal efficiency of an ORC can be significantly improved by incorporating turbine bleeding and regeneration, as it investigate in this paper.

Despite various studies concerning ORC like system performance modeling, selection of an appropriate working fluid, optimization, and etc., detailed energy and exergy analysis of the basic and different modified ORC cycles were rarely found. Energy analysis is the most commonly-used method for evaluation of energy conversion processes. However, it has some inherent limitations like not characterizing the energy quality and irreversibility of processes through the system. In contrast, exergy analysis will characterize the work potential of the systems. It provides a more realistic view of various devices and processes for evaluation of efficiency and exergy losses in order to locate the largest margins for improvements [\(Xu](#page-7-11) [et al.,](#page-7-11) [2011;](#page-7-11) [Dai](#page-7-12) [et al.,](#page-7-12) [2009;](#page-7-12) [Regulagadda](#page-7-13) [et al.,](#page-7-13) [2010;](#page-7-13) [Aljundi,](#page-7-14) [2009;](#page-7-14) [Sagastume](#page-7-15) [Gutiérrez](#page-7-15) [et al.,](#page-7-15) [2013\)](#page-7-15).

In this regard, the objective of this paper is to construct a theoretical framework for the energy and exergy analysis of the ORC, which can be used to evaluate the energy and exergy efficiencies and exergy destruction in each component and in the overall system. In addition to the basic ORC, three modified ORCs with regeneration and turbine bleeding are investigated to improve the system performance. This paper will identify major sources of loss and exergy destruction in the power plant. Finally, a parametric study is performed to determine how the system performance varies with different operating parameters.

#### **2. Thermodynamic approaches**

Schematics of a basic and modified cycles of ORC systems are shown in [Fig. 1.](#page-2-0) As observed in [Fig. 1\(](#page-2-0)a), there are four different processes: Process 1–2 (pumping process), Process 2–3 (constant pressure heat addition), Process 3–4 (expansion process), and

Process 4–1 (constant pressure heat removal). [Fig. 1\(](#page-2-0)b) shows a modified ORC incorporating turbine bleeding. Because the turbine outlet temperature is markedly higher than the condenser outlet temperature, implement of an internal heat exchanger (IHE) into the cycle is rewarded. For a modified ORC with regeneration (Fig.  $1(c)$ ), a feed-water heater is incorporated into the ORC. The vapor extracted from the turbine mixes with the feed-water exiting the pump. Ideally the mixture leaves the heater as a saturated liquid at the heater pressure. In addition, schematic of a modified ORC incorporating both regeneration and turbine bleeding is shown in [Fig. 1\(](#page-2-0)d).

The equations used to evaluate the basic and modified ORCs are presented in [Table 1.](#page-3-0) The topological methodology of [Mago](#page-7-16) [et al.](#page-7-16) [\(2008\)](#page-7-16), [Arslan](#page-7-17) [and](#page-7-17) [Yetik](#page-7-17) [\(2011\)](#page-7-17), [Dai](#page-7-18) [et al.](#page-7-18) [\(2009\)](#page-7-18) and [Desai](#page-7-10) [and](#page-7-10) [Bandyopadhyay](#page-7-10) [\(2009\)](#page-7-10) will be utilized to perform an energy and exergy analysis of ORC.

#### **3. Exergy analysis**

Exergy is a measure of the maximum capacity of a system to perform useful work as it proceeds to a specified final state in equilibrium with its surroundings. Exergy is generally not conserved as energy but destructed in the system. Exergy destruction is the measure of irreversibility that is the source of performance loss. Therefore, an exergy analysis assessing the magnitude of exergy destruction identifies the location, the magnitude and the source of thermodynamic inefficiencies in a thermal system [\(Aljundi,](#page-7-14) [2009\)](#page-7-14). Exergy flow rate of a system is composed of kinetic, potential, physical and chemical one [\(Aljundi,](#page-7-14) [2009;](#page-7-14) [Sagastume](#page-7-15) [Gutiérrez](#page-7-15) [et al.,](#page-7-15) [2013\)](#page-7-15):

$$
E = \mathbf{E}_k + \mathbf{E}_p + \mathbf{E}_{ph} + \mathbf{E}_{ch}.
$$
 (1)

<span id="page-3-0"></span>

|--|--|

Thermodynamic equations to evaluate ORCs.



And the specific exergy rate is:

$$
e = e_k + e_p + e_{ph} + e_{ch}
$$

$$
\stackrel{\bullet}{E}
$$

$$
(2)
$$

$$
e = \frac{L}{m}.
$$
 (3)  
In this study the kinetic  $(e_1)$  and potential  $(e_2)$  every are assuming

In this study the kinetic (*ek*) and potential (*ep*) exergy are assumingly negligible. The value of physical exergy for steam and water at various points in the objective system can be calculated by the following equation:

$$
e_{ph} = h - h_0 - T_0(s - s_0).
$$
 (4)

And for ideal gas,

$$
e_{ph} = h - h_0 - T_0 \left[ s - s_0 - RLn\left(\frac{P}{P_0}\right) \right]
$$
\n<sup>(5)</sup>

where *h* and *s* are specific enthalpy and entropy of the substance, respectively, and  $h_0$  and  $s_0$  are those at the state determined temperature and pressure ( $T_0$  and  $P_0$ ).

The chemical exergy of organic substance could be calculated from:

$$
e_{ch} = \frac{e_{ch}^o}{M} \left[ \frac{T_0}{298.15} \right] + \frac{\Delta H_0}{M} \left[ \frac{T_0 - 298.15}{298.15} \right] \tag{6}
$$

where  $\varDelta H_0$  and  $e_{ch}^o$  are standard enthalpy of devaluation and exergy of organic substance, respectively.

For the comprehensive exergy analysis, some important parameters are also calculated. The parameters are as follows [\(Mago](#page-7-16) [et al.,](#page-7-16) [2008\)](#page-7-16) and [\(Nikulshin](#page-7-19) [et al.,](#page-7-19) [2006\)](#page-7-19):

1-Degree of thermodynamic perfection  $(\alpha)$ :

 $\alpha_i$  is the ratio of the outlet exergy of element *i* ( $E_i^{\text{out}}$ ) to the exergy flow into the element  $i(E_i^{\text{in}})$ . It can be expressed as:

$$
\alpha_i = \frac{E_i^{\text{out}}}{E_i^{\text{in}}} = 1 - \frac{\varphi_i}{E_i^{\text{in}}} \tag{7}
$$

where  $\varphi_i$  is the exergy loss of element *i*:

$$
\varphi_i = E_i^{\text{in}} - E_i^{\text{out}}.\tag{8}
$$

Ideally  $\alpha$  of any element should be 1, which it will happen only when the exergy loss of the element is zero. Consequently, the higher degree of thermodynamic perfection of any element is the better performance of it.

The total exergy loss and degree of thermodynamic perfection of the system are as follows:

$$
\varphi_{\text{total}} = \sum_{i=1}^{n} \varphi_i \tag{9}
$$

$$
\alpha_{\text{total}} = \frac{E_{\text{total}}^{\text{out}}}{E_{\text{total}}^{\text{in}}}.
$$
\n(10)

2-Exergy efficiency

The exergy efficiency of element *i* is defined as the ratio of used exergy of element  $i(E_i^u)$  to the available exergy of the same element  $(E_i^a)$ :

$$
\eta_{\text{exergy}}^i = \frac{E_i^u}{E_i^a}.\tag{11}
$$

The available and used exergy of different elements of ORC system are presented in [Table 2.](#page-4-0) Obviously the higher exergy efficiency of any element is the better performance of that element.

The total exergy efficiency of system is the ratio of its total used exergy to total available exergy. It can be determined as:

$$
\eta_{\text{exergy,total}} = \frac{E_{\text{total}}^u}{E_{\text{total}}^a}.\tag{12}
$$

3-Influence coefficient

The influence coefficient of element *i* is defined as the ratio of the available exergy for element *i* to the total available exergy of the system  $(E_{total}^a)$ :

$$
\beta_i = \frac{E_i^a}{E_{\text{total}}^a}.\tag{13}
$$

Actually  $\beta$  is the weight of any element in the total system performance. This parameter identifies the elements of the system which has the most impact on the system efficiencies.

#### **4. Thermodynamic assumptions**

The considered working fluid for ORC is R-113 which has been proved to be a good candidate for ORC applications [\(Mago](#page-7-9) [et al.,](#page-7-9) [2008\)](#page-7-9) and [\(Badr](#page-7-20) [and](#page-7-20) [Ocallaghan](#page-7-20) [et al.,](#page-7-20) [1990;](#page-7-20) [Gu](#page-7-21) [et al.,](#page-7-21) [2009\)](#page-7-21). The evaporator pressure and condenser temperature are fixed at 2.5 MPa and 298 K, respectively. The isentropic efficiencies of the turbine and pump are 80 and 85%, respectively. The ORC receives heat from a heat source at a rate of 252 kW. The considered inlet hot gas to the evaporator is a steady stream of nitrogen at the temperature of 573 K and the pressure of 0.1 MPa. The determined temperature and pressure for the reference state are 298 K and 0.1 MPa. For the modified ORC with regeneration, the intermediate pressure of 1 MPa was assumed. Also, both pumps run at the same efficiency despite operating at different flow conditions. In addition, to perform thermodynamic analysis of the ORCs, steady state condition and no pressure drop and heat losses in any equipment are assumed.

### <span id="page-4-0"></span>**Table 2** Used and available exergies of the different components of an ORC [\(Sagastume](#page-7-15) [Gutiérrez](#page-7-15) [et al.,](#page-7-15) [2013\)](#page-7-15).



### <span id="page-4-1"></span>**Table 3**

Flow parameters for the basic ORC and ORC incorporating turbine bleeding.



<span id="page-4-2"></span>

Flow parameters for the ORC incorporating to regeneration and ORC incorporating both turbine bleeding and regeneration.



#### **5. Results**

#### *5.1. Exergy evaluation*

For calculation of exergy flow rates of the system, the operating conditions of the flows are needed. [Tables 3](#page-4-1)[–4](#page-4-2) present the flow parameter data for basic ORC and the modified ORCs. The tables include pressure, temperature, specific exergy, and exergy rate associated with each of the components.

Using the information provided in [Tables 3](#page-4-1)[–4,](#page-4-2) the evaporator heat rate, the condenser heat removal rate, the organic fluid mass flow rate, the pump power and the turbine power can be determined. All these values are arranged in [Table 5](#page-4-3) for the basic and modified ORCs.

[Tables 6–9](#page-5-0) present the thermodynamic characteristics of the analyzed basic and modified ORCs, respectively. The tables include parameters such as inlet and outlet exergy, exergy loss, used and available exergy, exergy efficiency, degree of thermodynamic perfection, and coefficient of influence associated with

#### <span id="page-4-3"></span>**Table 5**

Performance parameters of the basic and modified ORCs.



(a): basic ORC (b): ORC to turbine bleeding (c): ORC to regeneration (d): ORC to turbine bleeding and regeneration.

each component. In addition, the exergy loss, degree of thermodynamic perfection, and exergy efficiency for the total system are presented.



#### <span id="page-5-0"></span>**Table 6** Exergy evaluation of the basic ORC.

# **Table 7**

Exergy evaluation of the ORC incorporating turbine bleeding.

Element	$E_i^{in}$ (kW)	$E^{out}$ (kW)	(kW) $\Phi_i$	$E_i^u$ (kW)	$E_i^a$ (kW)	$\alpha_i$ (%)	$\beta_i$ (%)	$\eta_{\text{exergy}}^{l}$ (%)
Pump	2.2	2.05	0.146	2.05	2.2	93.34	0.012	93.34
Evaporator	172.151	137.23	34.9	70.64	105.56	79.7	62.11	66.92
Turbine	75.454	62.37	13.08	56.5	69.58	82.66	40.94	81.19
Condenser	2.008	1.75	0.25	1.75	2.008	87.4	1.18	87.4411
Heat exchanger	7.93	6.82	1.109	2.75	3.86	86	2.27	71.32177
Total system	169.54	120.03	49.50	56.5	169.9	70.8	$\qquad \qquad$	33.24

#### **Table 8**

Exergy evaluation of the ORC incorporating to regeneration.

Element	$E^{in}$ (kW)	$E^{out}$ (kW)	$\Phi_i$ (kW)	$E_i^u$ (kW)	$E_i^a$ (kW)	$\alpha_i$ (%)	$\beta_i$ (%)	$\eta_{\text{exergy}}^{l}$ (%)
Pump-1 Evaporator	37.93 211.5	37.89 192.41	0.041 19.09	3.148 86.87	3.19 105.96	99.88 90.9	0.018 61.29	98.68
Turbine	124.77	113.01	11.75	59.45	71.20	90.5	41.19	83.48
Condenser	3.75	3.13	0.61	3.134	3.75	83.56	2.17	83.56
Pump-2	0.7	0.66	0.033	0.66	0.7	95.17	0.404	95.17
Feed water	50.47	34.74	15.73	34.74	50.47	68.8	29.20	68.83
Total system	177.52	130.22	47.30	59.45	172.86	73.35	-	

#### **Table 9**





From the presented results [\(Tables 6–9\)](#page-5-0), it can be inferred that the basic ORC has the lowest exergy efficiency (31.2%) and the highest total exergy loss (50.9 kW). And also, the biggest part of the system exergy loss is related to evaporator. On the other hand it is concluded that the evaporator is the critical element in the ORC cycle [\(W.](#page-7-6) [Li](#page-7-6) [et al.,](#page-7-6) [2011\)](#page-7-6), due to the fact that evaporator has the highest exergy loss and influence coefficient in comparison with other components of the cycle. The exergy loss in the evaporator is mainly due to the irreversibility associated with heat transfer over a finite temperature difference [\(Mago](#page-7-16) [et al.,](#page-7-16) [2008\)](#page-7-16). In the basic ORC, exergy loss of evaporator is 37 kW and it is reduced by the modified ORCs incorporating turbine bleeding (ORC (b)), incorporating to regeneration (ORC (c)) and incorporating both turbine bleeding and regeneration (ORC (d)), 5.5%, 48.5% and 55%, respectively. This reduction in the exergy loss causes an improvement on the evaporator exergy efficiency from 64.2% (for the basic ORC) to 66.9%, 81.9% and 83.7% for the modified ORCs (b), (c) and (d), respectively. It is due to the used exergy in the evaporator increases for the modified cycles compared with the basic case. In addition, the decrease in the exergy loss entails an increase in the degree of thermodynamic perfection (DTP) from 77.7% (ORC (a)) to 79.7%, 90.9% and 92% for the ORCs (b), (c) and (d), respectively.

The most important result of energy and exergy analysis of the various ORCs is that the integrated ORCs with feed-water heater (ORCs (c) and (d)) show higher thermal and exergy efficiencies. Because the temperature of the evaporator feed is increased by bleeding of the working fluid from the turbine and mixing it with the evaporator feed in a direct contact heater. Moreover, an ORC with an internal heat exchanger (regenerator) and a direct contact heater presents the maximum thermal and exergy efficiencies (22.8% and 35.5%) among the evaluated cycles, in the same heat rate available for the evaporator from a hot gas stream (252 kW). On account of integration of an ORC with turbine bleeding and regeneration proposes additional benefits such as decrease in cold utility demand and generation of high power. However, it may be noted that the capital cost of the overall system and the complexity of the flow scheme are increased due to integration. In this way the high thermodynamic efficiency of ORC (d) makes decrease in the total system exergy loss (42.2 kW) and improvement on the degree of thermodynamic perfection (76%).

From the factor of coefficient of influence in [Tables 6–9,](#page-5-0) it can be clearly seen, that turbine is the second component that has more impact on the ORC performance. It displays the second highest coefficient of influence. The exergy loss of turbine for the basic ORC

<span id="page-6-0"></span>

**Fig. 2.** Percentage of the exergy destroyed in each component.

is 13.2 kW and it is descended in the modified ORCs (b), (c) and (d) by 0.9%, 11% and 29%, respectively.

To reach a deep understanding of exergy losses for other elements of the mentioned ORC cases, the percentage of the exergy destroyed in each component with respect to the total system exergy loss for four configurations are depicted in [Fig. 2.](#page-6-0) [Fig. 2](#page-6-0) proves that the evaporator and turbine are the components with the highest exergy losses contribution, respectively. In addition it can be seen that the ORCs (c) and (d) represent the lower exergy loss of evaporator. This exergy reduction is mainly due to the presence of the feed-water heater (33.5% and 35.7% of exergy losses for ORCs (c) and (d), respectively).

#### *5.2. Effect of evaporator pressure on the ORCs performance*

The variations of the thermal and exergy efficiencies against the evaporator pressure, for four ORC cases are shown in [Fig. 3.](#page-6-1) The turbine inlet temperature at saturated conditions and other operating conditions are same as before section. From [Fig. 3](#page-6-1) it can be inferred that for all ORC configurations the thermal efficiency increases with the increase in evaporator pressure from 1.8 to 3 MPa. While the integrated ORC to internal heat exchanger and feed-water heater presents the maximum efficiency compared to other cycles, it shows an increase in the thermal efficiency of 21.6%–23.5% for the lowest and highest turbine inlet pressures, respectively.

In [Fig. 3,](#page-6-1) the exergy efficiency also increases with evaporator pressure increasing, and the ORC (d) is still the highest, ORCs (c) and (b) are the second and third highest and the basic ORC has the lowest exergy efficiency. The exergy efficiency becomes larger because of reduction in the system total exergy loss with the increment in the evaporator pressure, which is shown in [Fig. 4.](#page-6-2) Since the evaporator pressure is increased, the discrepancy between the evaporator temperature and the hot gas stream temperature entering the evaporator is reduced. This reduction in the temperature difference leads to increment in the used exergy and it causes an improvement in the exergy efficiency or a decrease in the system exergy loss.

<span id="page-6-1"></span>

<span id="page-6-2"></span> $54$  $P=1.8$  bar  $P=2.5$  bar  $P=3$  har  $P=2$  har  $P=2.7$  has 52 50  $loss (KW)$  $48$ Exergy  $46$  $44$  $42$  $4($ ORC (a) ORC (c)  $ORC(b)$  $ORC$  $(d)$ 

**Fig. 3.** Variations of the thermal and exergy efficiencies versus evaporator pressure.

**Fig. 4.** Variations of the exergy loss versus evaporator pressure.

Moreover, the lessening in the exergy loss entails a growth in the degree of thermodynamic perfection (DTP) of the system. The

<span id="page-7-22"></span>

**Fig. 5.** Variations of DTP of total system versus evaporator pressure.

variations of overall system DTP against evaporator pressure are depicted in [Fig. 5.](#page-7-22)

#### **6. Conclusions**

This paper presents a detailed energy and exergy analysis of a basic as well as three modified Organic Rankine Cycles (ORCs) using R-113 as working fluid. The modified ORCs considered incorporating turbine bleeding (ORC (b)), regeneration (ORC (c)) and both of them (ORC (d)). For a comprehensive thermodynamic analysis, some important parameters such as degree of thermodynamic perfection, exergy efficiency, and influence coefficient are also calculated.

The results show that the basic ORC has the lowest exergy efficiency (31.2%) and the highest total exergy loss (50.9 kW). And the biggest part of the system exergy loss is related to evaporator (37 kW). The modified ORCs (b), (c) and (d) improve the evaporator exergy losses by 5.5%, 48.5% and 55%, respectively. It is due to increase in evaporator feed temperature by bleeding with working fluid from the turbine in a direct contact heater. Reduction in the total exergy losses by modified ORCs lead to increment in the overall system exergy efficiency by 6.5%, 10% and 14%, respectively.

The integrated ORC to regenerator and a feed-water heater (ORC (d)) presents the maximum thermal and exergy efficiencies (22.8% and 35.5%) among the evaluated cycles, on account of additional benefits such as decrease in cold utility demand and generation of high power. Consequently the total system exergy loss is decreased in 42.2 kW and the degree of thermodynamic perfection is improved to 76%.

The results show that for four cycles the thermal and exergy efficiencies increase and the system exergy loss decreases with the evaporator pressure increasing. In this way the discrepancy between the evaporator temperature and the hot gas stream temperature entering the evaporator is reduced. So the used exergy and the exergy efficiency are improved.

#### **References**

- <span id="page-7-14"></span>Aljundi, I.H., [2009. Energy and exergy analysis of a steam power plant in Jordan.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref1) Appl. Therm. Eng. 29, 324–328.
- <span id="page-7-17"></span>Arslan, O., Yetik, O., 2011. ANN based optimization of supercritical ORC-Binary ge[othermal power plant: Simav case study. Appl. Therm. Eng. 31, 3922–3928.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref2) Badr, O., Ocallaghan, P.W., et al., 1990. Rankine-cycle systems for harnessing power
- <span id="page-7-20"></span>fro[m low-grade energy-Sources. Appl. Eng. 36, 263–292.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref3) Bombarda, P., Invernizzi, C.M., Pietra, C., 2010. Heat recovery from diesel engines: A
- <span id="page-7-0"></span>the[rmodynamic comparison between Kalina and ORC cycles. Appl. Therm. Eng.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref4) 30, 212–219.
- <span id="page-7-2"></span>Chacartegui, R., Muñoz de Escalona, J.M., Sánchez, D., Monje, B., Sánchez, T., 2011. Alt[ernative cycles based on carbon dioxide for central receiver solar power](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref5) plants. Appl. Therm. Eng. 31, 872–879.
- <span id="page-7-12"></span>Dai, Y.P., Wang, J.F., Gao, L., 2009. Exergy analysis, parametric analysis and opt[imization for a novel combined power and ejector refrigeration cycle. Appl.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref6) Therm. Eng. 29, 1983–1990.
- <span id="page-7-18"></span>Dai, Y., Wang, J., Gao, L., 2009. Parametric optimization and comparative study of org[anic Rankine cycle \(ORC\) for low grade waste heat recovery. Eng. Convers.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref7) Manage. 50, 576–582.
- <span id="page-7-10"></span>Desai, N.B., Bandyopadhyay, S., [2009. Process integration of organic Rankine cycle.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref8) Eng. 34, 1674–1686.
- <span id="page-7-21"></span>Gu, W., Weng, Y., Wang, Y., Zheng, B., 2009. Theoretical and experimental inv[estigation of an Organic Rankine Cycle for a waste heat recovery system.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref9) Part A: J. Power. Eng. 223, 523–533. Proc. IMechE.
- <span id="page-7-3"></span>Karellas, S., Schuster, A., Leontaritis, A.D, 2012. Influence of supercritical ORC par[ameters on plate heat exchanger design. Appl. Therm. Eng. 33–34, 70–76.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref10)
- <span id="page-7-6"></span>Li, W., Feng, X., Yu, L.J., Xu, J., 2011. Effects of evaporating temperature and internal he[at exchanger on organic Rankine cycle. Appl. Therm. Eng. 31, 4014–4023.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref11)
- <span id="page-7-7"></span>Li, J., Pei, G., Li, Y., Ji, J., 2011. Evaluation of external heat loss from a small-scale
- <span id="page-7-9"></span>ex[pander used in Organic Rankine cycle. Appl. Therm. Eng. 31, 2694–2701.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref12) Mago, P.J., Chamra, L.M., Srinivasan, K., Somayaji, C., 2008. An examination of reg[enerative organic rankine cycle using dry fluids. Appl. Therm. Eng. 28,](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref13) 998–1007.
- <span id="page-7-16"></span>Mago, P.J., Srinivasan, K.K., Chamra, L.M., Somayaji, C., 2008. An examination of ex[ergy destruction in organic Rankine cycles. Int. J. Eng. Res. 32, 926–938.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref14)
- <span id="page-7-1"></span>Muñoz de Escalona, J.M., Sánchez, D., Chacartegui, R., Sánchez, T., 2012. Part-load an[alysis of gas turbine & ORC combined cycles. Appl. Therm. Eng. 36, 63–72.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref15)
- <span id="page-7-19"></span>Nikulshin, V., Bailey, M., Nikulshina, V., 2006. Thermodynamic analysis of air
- <span id="page-7-8"></span>ref[rigerator on exergy graph. Therm. Sci. 10, 99–110.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref16) Quoilin, S., Declaye, S., Tchanche, BF., Lemort, V., 2011. Thermo-economic opt[imization of waste heat recovery Organic Rankine Cycles. Appl. Therm. Eng.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref17) 31, 2885–2893.
- <span id="page-7-13"></span>Regulagadda, P., Dincer, I., Naterer, G.F., 2010. Exergy analysis of a thermal power pla[nt with measured boiler and turbine losses. Appl. Therm. Eng. 30, 970–976.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref18)
- <span id="page-7-15"></span>Sagastume Gutiérrez, A., Cogollos Martínez, J.B., Vandecasteele, C., 2013. Energy and ex[ergy assessments of a lime shaft kiln. Appl. Therm. Eng. 51, 273–280.](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref19)
- <span id="page-7-4"></span>Sun, J., Li, W., [2011. Operation optimization of an organic rankine cycle \(ORC\) heat](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref20) recovery power plant. Appl. Therm. Eng. 31, 2032–2041.
- <span id="page-7-5"></span>Wei, D., Lu, X., Lu, Z., Gu, J., 2008. Dynamic modeling and simulation of an Organic Ra[nkine Cycle \(ORC\) system for waste heat recovery. Appl. Therm. Eng. 28,](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref21) 1216–1224.
- <span id="page-7-11"></span>Xu, Ch., Wang, Zh., Li, X., Sun, F., [2011. Energy and exergy analysis of solar power](http://refhub.elsevier.com/S2352-4847(14)00008-0/sbref22) tower plants. Appl. Therm. Eng. 31, 3904–3913.